



**Facilities Design and Construction
San Francisco Unified School District**

135 Van Ness Avenue
San Francisco, CA 94102
Phone: (415)355-6979 Fax: (415)355-6988

September 15, 2023

SFUSD takes our responsibility to provide a safe and healthy environment for the children and staff seriously. In partnership with the San Francisco Public Utilities Commission (SFPUC), all cold-water outlets at the site below used for drinking and food preparation have been tested for lead. Any outlet with a result over 5 parts per billion (ppb) was immediately taken out of service. Water filler stations were provided for students and staff in areas impacted by the test results if requested by site administration.

The District is currently completing an assessment of remediation options at every outlet with a result over 5 ppb. Outlets that tested above 5 ppb will be scheduled for future remediation work. After the remediation, the outlet will be retested for compliance before it is put back in service. No outlet will be placed back in service unless it is tested with a result of less than 5 ppb.

**Results for:
Buena Vista Horace Mann K-8
3351 23rd Street, San Francisco, CA 94110**

The following water outlets had a lead level AT OR ABOVE the 5 parts per billion (ppb) action level. The location of outlets with a result over 5 ppb are in the table below.

Room	Fixture Type	Reference Sample #
Classroom 301	Sink Faucet (C only) and Eyewash Fixture	U
Classroom 304	Sink Faucet (H&C) and Drinking Faucet	Y & Z
Classroom 304	Sink Faucet *H&C)	1
Classroom 304	Sink Faucet (H&C)	2
Classroom 306	Sink Faucet (C only) and Drinking Faucet	3
Parent Resource Room off Cafeteria	Sink Faucet (H&C)	43
Prep Room 300 between Rooms 301 and 303	Sink Faucet (H&C) and Drinking Faucet	W & X
Toilet Room between 304 and 306	Sink Faucet (C only)	R13
Kitchen 123E	Sink Faucet (H&C)	37
All Gender Restroom outside Gymnasium 121	Sink Faucet (H&C)	R18